



Specification Data -- RESILIENT TILE FLOORING 09 65 19

Burke Flooring 12" X 12" Marbled Rubber Floor Tile

PART 1 GENERAL

1.01 THIS SECTION INCLUDES;

- A. Flooring and accessories as shown on the drawings and schedules and as indicated by the requirements of this section.

1.02 RELATED DOCUMENTS

- A. Drawings and General Provisions of the Contract (including General and Supplementary Conditions and Division 1 sections) apply to the work of this section.

1.03 RELATED SECTIONS

- A. Other Division 9 sections for floor finishes related to this section but not the work of this section.
- B. Division 3 Concrete; not the work of this section.

1.04 QUALITY ASSURANCE AND REGULATORY REQUIREMENTS

- A. Use an installer who is competent in the installation of Burke Marbled Tile.
- B. If required, provide resilient flooring and accessories including leveling and patching compounds, and adhesives.
- C. If required, provide flooring material to meet the following fire test performance criteria as tested by a recognized independent testing laboratory:
 - a. ASTM E 648 Critical Radiant Flux of 0.45 watts per sq. cm. or greater, Class I.
 - b. ASTM E 662 (Smoke Generation) Maximum Specific Optical Density of 450 or less.

1.05 SUBMITTALS

- A. Submit shop drawings and manufacturer's technical data, installation and maintenance instructions for flooring and accessories.
- B. Submit the manufacturer's standard samples showing the required colors for flooring and applicable accessories.

1.06 ENVIRONMENTAL CONDITIONS

- A. Deliver materials to the jobsite in the manufacturer's original unopened boxes that bear the name and brand of the manufacturer and project identification.
- B. Store materials in an enclosed space, off the ground, and protected from the weather. Protect adhesives from freezing. Store flooring, adhesives and accessories in the spaces where they will be installed to acclimate for at least 48 hours before beginning installation.
- C. Maintain a minimum temperature in the spaces to receive the flooring and accessories of 65°F (18°C) and a maximum temperature of 85°F (29°C) for at least 48 hours before, during, and for not less than 48 hours after installation.
- D. Do not install flooring over concrete slabs until they are sufficiently dry to achieve a bond with the adhesive, in accordance with the manufacturer's recommended bond and moisture tests.
- E. Install flooring and accessories after the other finishing operations, including painting, have been completed. Close spaces to traffic during the installation of the flooring.

PART 2 PRODUCTS**2.01 RESILIENT FLOOR TILE 12" X 12" SMOOTH MARBLED**

- A. Manufacturer/Products: Burke Flooring Products; Rubber Floor Tile
- B. Products/Description: Marbled molded rubber floor tile
 - 1. Floor Tile Size: 12" x 12" (304.800 mm x 304.800 mm).
 - 2. Thickness: (gauge) .125" (3.175 mm).
 - 3. Color: Selection from Burke's standard array, Marble Tile Color Palette.
 - 4. Substrate adhesives pursuant to Burke Flooring recommendations.
 - 5. Conformance:
 - a. ASTM F-1344, Class 1B; FS SS-T-312b, Type II.
 - b. ASTM D-2047 Static Coefficient of Friction. Exceeds ADA requirement.
 - c. ASTM D-2240 Hardness Shore A; not less than 90.
 - d. ASTM E-84 Class B; (Class A upon special order).
 - e. ASTM E-648/NFPA 253; Class 1 Fire Rating.
- C. Flooring shall meet composition, size, thickness, squareness, flexibility, residual indentation, resistance to chemicals, resistance to heat and resistance to light requirements of ASTM F 1344, "Standard Specification for Rubber Floor Tile," Class I, Type B – Smooth Surface.

2.02 ADHESIVES

- A. Provide [Burke BR 711 Flooring Adhesive] [BR721 Solvent Free, Two Part Epoxy Adhesive] for tile installation.

2.03 ACCESSORIES

- A. For patching, smoothing, and leveling monolithic sub-floors (concrete, terrazzo, quarry tile, ceramic tile, and certain metals), provide cementitious based with a minimum compressive strength of 3,500 psi.
- B. Provide transition/reducing strips tapered to meet abutting materials.
- C. Provide threshold of thickness and width as shown on the drawings.
- D. Provide resilient edge strips of width shown on the drawings, of equal gauge to the flooring, homogeneous vinyl composition, tapered or bullnose edge, with color to match or contrast with the flooring, or as selected by the Architect from standard colors available.
- E. Provide metal edge strips of width shown on the drawings and of required thickness to protect exposed edges of the flooring. Provide units of maximum available length to minimize the number of joints. Use butt-type metal edge strips for concealed anchorage, or overlap-type metal edge strips for exposed anchorage. Unless otherwise shown, provide strips made of extruded aluminum with a mill finish.

PART 3 EXECUTION

3.01 INSPECTION

- A. Examine subfloors prior to installation to determine that surfaces are smooth and free from cracks, holes, ridges, and other defects that might prevent adhesive bond or impair durability or appearance of the flooring material.
- B. Inspect subfloors prior to installation to determine that surfaces are free from curing, sealing, parting and hardening compounds; residual adhesives; adhesive removers; and other foreign materials that might prevent adhesive bond. Visually inspect for evidence of moisture, alkaline salts, carbonation, dusting, mold, or mildew.
- C. Report conditions contrary to contract requirements that would prevent a proper installation. Do not proceed with the installation until unsatisfactory conditions have been corrected.
- D. Failure to call attention to defects or imperfections will be construed as acceptance and approval of the subfloor. Installation indicates acceptance of substrates with regard to conditions existing at the time of installation.

3.02 PREPARATION

- A. Smooth concrete surfaces, removing rough areas, projections, ridges, and bumps, and filling low spots, control or construction joints, and other defects with fast-setting cement-based underlayment or fast-setting cement-based patch and skim coat as recommended by the flooring manufacturer.
- B. Remove paint, varnish, oils, release agents, sealers, and waxes. Remove residual adhesives as recommended by the flooring manufacturer. Remove curing and hardening compounds not compatible with the adhesives used, as indicated by a bond test or by the compound manufacturer's recommendations for flooring. Avoid organic solvents.
- C. Perform subfloor Calcium Chloride Tests (and Bond Tests) to determine if surfaces are dry; free of curing and hardening compounds, old adhesive and other coatings; and ready to receive flooring.
- D. Vacuum or broom-clean surfaces to be covered immediately before the application of flooring. Make subfloor free from dust, dirt, grease, and all foreign materials.

3.03 INSTALLATION OF FLOORING

- A. Install flooring in strict accordance with the latest edition Burke Flooring Marble Tile Installation Instructions. Install flooring wall to wall before the installation of floor-set cabinets, casework, furniture, equipment, movable partitions, etc. Extend flooring into toe spaces, door recesses, closets, and similar openings as shown on the drawings.
- B. If required, install flooring on pan-type floor access covers. Maintain continuity of color and pattern within pieces of flooring installed on these covers. Adhere flooring to the subfloor around covers and to covers.
- C. Scribe, cut, and fit to permanent fixtures, columns, walls, partitions, pipes, outlets, and built-in furniture and cabinets. Install flooring with adhesives, tools, and procedures in strict accordance with the manufacturer's written instructions. Observe the recommended adhesive trowel notching, open times, and working times.

3.05 CLEANING AND PROTECTION

- A. Perform initial maintenance according to Burke Flooring Maintenance Instructions.
- B. Protect installed flooring as recommended by the flooring manufacturer against damage from rolling loads, other trades, or the placement of fixtures and furnishings.